



## LEGENDA DISTANZE DI SICUREZZA PER INSTALLAZIONE SERBATOI DI GPL

| <b>INTERRATI</b>         | <b>A</b> | <b>B</b> | <b>C</b> | <b>D</b> |
|--------------------------|----------|----------|----------|----------|
| Fino a 3 m <sup>3</sup>  | 2,50 m   | 5,00 m   | 7,50 m   | 1,50 m   |
| Da 3 a 5 m <sup>3</sup>  | 3,75 m   | 7,50 m   | 7,50 m   | 1,50 m   |
| Da 5 a 13 m <sup>3</sup> | 7,50 m   | 11,00 m  | 7,50 m   | 3,00 m   |

| <b>FUORI TERRA</b>       | <b>A</b> | <b>B</b> | <b>C</b> | <b>D</b> |
|--------------------------|----------|----------|----------|----------|
| Fino a 3 m <sup>3</sup>  | 5,00 m   | 10,00 m  | 15,00 m  | 3,00 m   |
| Da 3 a 5 m <sup>3</sup>  | 7,50 m   | 15,00 m  | 15,00 m  | 3,00 m   |
| Da 5 a 13 m <sup>3</sup> | 15,00 m  | 22,00 m  | 15,00 m  | 6,00 m   |

